




(1)Main voltage	Nominal value	For
	2.3KV	+10%-15%
	3.3KV	+10%-15%
	4.16KV	+10%-15%
	6.0KV	+10%-15%
	6.6KV	+10%-15%
	10KV	+10%-15%
(2)Rated current	60A---1450A	
(3)Control supply voltage	Nominal value	For
Default 220VAC	110VAC	100~120VAC
	220VAC	200~240VAC
	110VDC	100~120VDC
	220VDC	200~240VDC
(4)Options	Code	Introducti on
Note:For more than one option indicate for example 1+3	1	RS485-Modbus RTU
	2	RS485-Profibus DP
	3	Analogue output
	4	Touch screen