

Test Report

No.: DR50120303L

Applicant	:	LG Industrial Systems Co., Ltd. San 181, Samsung-Ri, Mokchon-Myun, Chonan-Si, Chungnam, Korea		
Manufacturer	:	LG Industrial Systems Co., Ltd. San 181, Samsung-Ri, Mokchon-Myun, Chonan-Si, Chungnam, Korea		
Test Item	:	Programmable Logic Controller		
Model No.	:	MK120S Series		
Test Standard	:	Electromagnetic Compatibility Directive 89/336/EEC * 61000-6-4:2001 61000-6-2:2001 * (EN61000-4-2: 1995+A1: 1998+A2:2001) (EN61000-4-3: 1996+A1:1998+A2:2001) * (EN61000-4-4: 1995+A1:2001) * (EN61000-4-5: 1995+A1:2001) (EN61000-4-6: 1996+A1:2001) * (EN61000-4-11: 1994+A1:2001)		
Tested Date	:	March 07 ~19, 2003		
Date of Issue	:	March 20, 2003		
Test Result	:	Passed		
Tested by :		Reviewed by :		
 <u>S.U.HAN</u> Name Signature		 <u>C.H.AHN</u> Name Signature		
Other Aspects :				
Abbreviations : OK, Pass = passed , Fail = failed , N/A = not applicable				
This test result only responds to the tested sample. It is not allowed to copy this report even partly without the allowance of the test laboratory. This report must not be used by the applicant to claim product endorsement by NVLAP or any agency of the U.S.Government. The test items of "*" marked are NVLap scope.				



NVLAP LAB CODE 200559-0